



Form CP-Valve Kit M6 (Version A.1)
Obsoletes Form CP-Valve Kit M6 (Version A)

Applies to: **Replacement
Natural Gas Valve
for Valve Code M6**

Replacement Valve Kit P/N 222037 (replaces natural gas valve, P/N 96309, Valve Code M6)

Application Natural gas valve P/N 96309 identified in a heater serial number as Code M6 is no longer available. Use Kit P/N 222037 as a replacement.

Components Kit P/N 222037 includes:

Qty	P/N	Description
1	221525	3/4 x 3/4 Gas Valve, Natural Gas, 36H32-441
1	97572	1/8" Male Compression Nut
1	222038	Instruction Sheet, Form CP-Valve Kit M6

- Instructions**
- 1) Change the compression nut.** The valve being replaced has a 1/8" compression nut at the pilot tubing connection. The replacement valve has a 1/4" compression nut. Before installing the valve, remove the compression fitting from the new valve and install the 1/8" fitting provided in the kit.
 - 2) Install the replacement valve.** Use pipe joint compound that is resistant to liquefied petroleum gas. Field-supplied gas supply piping adjustments may be required.
 - 3) Leak test all joints with a leak-testing solution.**

WARNING

All components of a gas supply system must be leak tested prior to placing equipment in service. NEVER TEST WITH AN OPEN FLAME.

- 4) Turn the gas on and operate the heater. Check all safety features for proper operation.**



www.ReznorHVAC.com; (800) 695-1901

©2015 Reznor LLC, All rights reserved.

Trademark Note: Reznor® is registered in the United States.

All other trademarks are the property of their respective owners.

05/15 Form CP-Valve Kit M6 (Version A.1) P/N 222038 Rev 2